

## 2021 Lead in Drinking Water Statement of Assurance

Farmingdale Public School  
49 Academy Street  
Farmingdale, New Jersey 07727

Sent via e-mail: [Leadtesting@doe.state.nj.us](mailto:Leadtesting@doe.state.nj.us)

To whom it may concern:

On Saturday December 11, 2021, the Farmingdale Public School located at 49 Academy Street, Farmingdale, New Jersey conducted lead in drinking water sampling. The lead in drinking water sampling was conducted in accordance with the New Jersey Schools Lead in Drinking Water Regulations; N.J.A.C. 6A:26-1.2;12.4 and the USEPA "3 T's for Reducing Lead in Drinking Water in Schools". A total of seventy-four (24) initial and flush samples were taken from all drinking water outlets to which a student or staff member has or may have access to Farmingdale Public School facility. From the seventeen analytical results, all but seven were found to be below the action level of 15ppb.

Name of NJ Certified Laboratory who performed the analytical testing and certification number:

Name: Alpha Analytical Inc Certification Number: MA015

Please see the below checklist indicating all required steps were taken to meet the regulatory requirements of N.J.A.C 6A:26 1.2 and 12.4.

- ✓ QAPP signed by all parties involved in sampling (Program Manager, Project Manager, Individual School Project Officers, Laboratory Manager, Laboratory QA Officer)
- ✓ Sampling conducted in accordance with a Lead Sampling Plan
- ✓ Completed Plumbing Profile (Attachment B)
- ✓ Completed Water Outlet Inventory (Attachment C)
- ✓ Completed Filter Inventory (Attachment D)
- ✓ Completed Flushing Log (Attachment E)

- ✓ Completed data packages for each sampling event including Chain of Custody sheets, field notes, results report and Excel spreadsheet
- ✓ Ensured all results reported to at least 3 significant figures
- ✓ Ensured no results above 100 µg/l
- ✓ Compared field notes/ Chain of Custody notes with sampling results
- ✓ Ensured all outlets were operational and sampled
- ✓ Ensured all sample codes are identified on the Key Code
- ✓ Verified that water outlets requiring flushing were properly flushed
- ✓ Compared first draw samples with follow-up flush samples
- ✓ Completed filter inventory with date installed, replacement frequency and determined if they were NSF certified for lead reduction
- ✓ Farmingdale Public School has made the results of all water samples publicly available at the school facility and on the Farmingdale Public School website.

Superintendent Name (Print): Edith Conroy  
Signature: Edith Conroy Date: 5/31/23